



Product Service

Attestation of Conformity

No. E8A 084937 0040 Rev. 00

Holder of Certificate: **Canadian Solar Inc.**
545 Speedvale Ave West
Guelph Ontario N1K1E6
CANADA

Name of Object: **Converter**
Grid-Tied Inverter

Model(s): **CSI-100KTL-GI-E, CSI-125KTL-GI-E,**
CSI-125K-T600GL02-E

Description of Object:

Input voltage:	DC 860V~1450V
Max. input power:	150kW, 187.5kW, 187.5kW
Rated output voltage:	AC 600V/3Ø(connected to the grid with transformer)
Rated frequency:	50Hz
Rated output power:	100kW, 125kW, 125kW
Protection class:	I

Tested according to: EN 61000-6-2:2005
EN 61000-6-4:2007/A1:2011

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 4812820020000

Date, 2020-09-25

(Jun Bao)

Page 1 of 1

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.